



Town of Yorktown

9800 W Smith St • PO Box 518

Yorktown, IN 47396

765-759-4003p • 765-759-4016f

www.yorktownindiana.org

7/15/2020

Well Cleaning and Pump rebuild

As part of our annual inspection, Peerless is recommending that we perform a well cleaning and pump rebuild on Well 3. The cleaning has not been performed in approximately 10 years, which means that the cleaning is due. In addition they've tested the pump and it is not performing at peak operation or efficiency. Both of these items are part of ongoing maintenance for the operation of water wells, cleaning typically are called for after 7-8 years, due to the new well coming online we opted to push the well an additional year to make sure that our system did not see a water shortage issue. The accounting for water operation sets money back annually to help cover costs associated with this type of item, I would recommend approval of the cleaning/rebuild to be paid for from the depreciation account.

Respectfully,

Pete Olson
Town Manager